



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 03/06/2019  
Received: 02/20/2019  
Sampled By: Tony Tiano  
Work Order: 9051011

**C** Molalla River School District  
**L** Attn: Frederic Dettwyler  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # : 4190529

Sampling Location: Rural Dell Elem.  
Sample Matrix: Drinking Water

**Lab Number**

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>9051011-01</b> Sample Name: Rm 1 Sampled: 2/20/19 7:45							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-02</b> Sample Name: Rm 2 Sampled: 2/20/19 7:47							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-03</b> Sample Name: Rm 3 Sampled: 2/20/19 7:50							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-04</b> Sample Name: Rm 4 Sampled: 2/20/19 7:51							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-05</b> Sample Name: Rm 5 Sampled: 2/20/19 7:52							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-06</b> Sample Name: Rm 6 Sampled: 2/20/19 7:55							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 03/06/2019  
Received: 02/20/2019  
Sampled By: Tony Tiano  
Work Order: 9051011

**C** Molalla River School District  
**L** Attn: Frederic Dettwyler  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**

Project # : N/A  
PWSID # : 4190529

Sampling Location: Rural Dell Elem.  
Sample Matrix: Drinking Water

**Lab Number**

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>9051011-07</b> Sample Name: Rm 7 Sampled: 2/20/19 7:55							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-08</b> Sample Name: Rm 8 Sampled: 2/20/19 7:57							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-09</b> Sample Name: Rm 9 Sampled: 2/20/19 7:58							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00
<b>9051011-10</b> Sample Name: Rm 10 Sampled: 2/20/19 8:01							
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	03/06/19 12:20
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	02/22/19 15:00

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
**A** = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 03/27/2019  
Received: 03/19/2019  
Sampled By: Frederic Dettwyler  
Work Order: 9078051

**C** **Molalla River School District**  
**L** Attn: Frederic Dettwyler  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # : 4190529

Sampling Location: Rural Dell  
Sample Matrix: Water

**Lab Number**

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>9078051-01</b>	<b>Sample Name:</b> Well Head						
	<b>Sampled:</b> 3/19/19 7:45						
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.020	1.3	03/26/19 14:58
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	03/22/19 13:13

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
**A** = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

APR 01 2019

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director



13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 09/26/2016  
Received: 09/08/2016  
Sampled By: Rick Dettwyler  
Work Order: 6252035

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # : 4190529

Sampling Location: Rural Dell 10500 S Hyway 211

**Lab Number**

Lab Number	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>6252035-01</b>	Sample Name: Rm 1 Sampled: 9/8/16 7:05		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	<b>0.0261</b>	0.0020	0.015	09/21/16 16:46 <b>MCL</b> E
<b>6252035-02</b>	Sample Name: Rm 2 Sampled: 9/8/16 7:07		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	<b>0.0154</b>	0.0020	0.015	09/21/16 16:46
<b>6252035-03</b>	Sample Name: Rm 3 Sampled: 9/8/16 7:10		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0095	0.0020	0.015	09/21/16 16:46
<b>6252035-04</b>	Sample Name: Rm 4 Sampled: 9/8/16 7:12		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	<b>0.0153</b>	0.0020	0.015	09/21/16 16:46
<b>6252035-05</b>	Sample Name: Rm 5 Sampled: 9/8/16 7:15		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0086	0.0020	0.015	09/21/16 16:46
<b>6252035-06</b>	Sample Name: Rm 6 Sampled: 9/8/16 7:18		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0128	0.0020	0.015	09/21/16 16:46



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 09/26/2016  
Received: 09/08/2016  
Sampled By: Rick Dettwyler  
Work Order: 6252035

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # : 4190529

Sampling Location: Rural Dell 10500 S Hyway 211

**Lab Number**

Lab Number	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>6252035-07</b>	Sample Name: Rm 7 Sampled: 9/8/16 7:20		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0121	0.0020	0.015	09/21/16 16:46
<b>6252035-08</b>	Sample Name: Rm 8 Sampled: 9/8/16 7:22		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0083	0.0020	0.015	09/21/16 16:46
<b>6252035-09</b>	Sample Name: Rm 9 Sampled: 9/8/16 7:25		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0024	0.0020	0.015	09/21/16 16:46
<b>6252035-10</b>	Sample Name: Rm 10 Sampled: 9/8/16 7:28		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0046	0.0020	0.015	09/21/16 16:46

**MCL** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit

**MCL** = Maximum Contamination Limit

†All procedures for this analysis conform to NELAC standards.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 08/09/2016  
Received: 06/28/2016  
Sampled By: Tony Tiano/Ric Det  
Work Order: 6180033

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**


**Project:** Rural Dell Elementary  
Project # : N/A  
PWSID # : 4190529

Sampling Location:

**Lab Number**

Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>6180033-01</b> Sample Name: Rm 1 Sampled: 6/27/16 15:04 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	<b>0.0243</b>	0.0020	0.015	08/08/16 16:03 MCLE
<b>6180033-02</b> Sample Name: Rm 2 Sampled: 6/27/16 15:07 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	0.0115	0.0020	0.015	08/08/16 16:03
<b>6180033-03</b> Sample Name: Rm 3 Sampled: 6/27/16 15:08 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	<b>0.0389</b>	0.0020	0.015	08/08/16 16:03 MCLE
<b>6180033-04</b> Sample Name: Rm 4 Sampled: 6/27/16 15:08 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	<b>0.0414</b>	0.0040	0.015	08/08/16 16:03 MCLE
<b>6180033-05</b> Sample Name: Rm 5 Sampled: 6/27/16 15:11 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	<b>0.0207</b>	0.0020	0.015	08/08/16 16:03 MCLE
<b>6180033-06</b> Sample Name: Rm 6 Sampled: 6/27/16 15:10 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	0.0056	0.0020	0.015	08/08/16 16:03





**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 08/09/2016

Received: 06/28/2016

Sampled By: Tony Tiano/Ric Det

Work Order: 6180033

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:** Rural Dell Elementary  
Project # : N/A  
PWSID # : 4190529

Sampling Location:

**Lab Number**

Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>6180033-07</b> Sample Name: Rm 7 Sampled: 6/27/16 15:13 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	0.0109	0.0020	0.015	08/08/16 16:03
<b>6180033-08</b> Sample Name: Rm 8 Sampled: 6/27/16 15:14 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	0.0093	0.0020	0.015	08/08/16 16:03
<b>6180033-09</b> Sample Name: Rm 9 Sampled: 6/27/16 15:17 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	0.0033	0.0020	0.015	08/08/16 16:03
<b>6180033-10</b> Sample Name: Rm 10 Sampled: 6/27/16 15:18 Matrix: Water						
<i>Metals (Total)</i>						
†Copper	1055 SM3111B	mg/L	ND	0.050	1.3	08/08/16 13:10
†Lead	1030 EPA 200.9	mg/L	ND	0.0020	0.015	08/08/16 16:03

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL **MRL** = Minimum Reporting Limit

**MCL** = Maximum Contamination Limit

†All procedures for this analysis conform to NELAC standards.

Approved by:

Adriana Gonzalez-Gray  
Laboratory Director



13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 09/26/2016

Received: 09/08/2016

Sampled By: Rick Dettwyler

Work Order: 6252035

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**

Project # : N/A


PWSID # : 4190529

Sampling Location: Rural Dell 10500 S Hyway 211

**Lab Number**

Lab Number	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>6252035-01</b>	Sample Name: Rm 1 Sampled: 9/8/16 7:05		Sample Composition: Raw Distribution Single		Matrix: Drinking Water		
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	<b>0.0261</b>	0.0020	0.015	09/21/16 16:46 MCL
<b>6252035-02</b>	Sample Name: Rm 2 Sampled: 9/8/16 7:07		Sample Composition: Raw Distribution Single		Matrix: Drinking Water		
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	<b>0.0154</b>	0.0020	0.015	09/21/16 16:46
<b>6252035-03</b>	Sample Name: Rm 3 Sampled: 9/8/16 7:10		Sample Composition: Raw Distribution Single		Matrix: Drinking Water		
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	0.0095	0.0020	0.015	09/21/16 16:46
<b>6252035-04</b>	Sample Name: Rm 4 Sampled: 9/8/16 7:12		Sample Composition: Raw Distribution Single		Matrix: Drinking Water		
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	<b>0.0153</b>	0.0020	0.015	09/21/16 16:46
<b>6252035-05</b>	Sample Name: Rm 5 Sampled: 9/8/16 7:15		Sample Composition: Raw Distribution Single		Matrix: Drinking Water		
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	0.0086	0.0020	0.015	09/21/16 16:46
<b>6252035-06</b>	Sample Name: Rm 6 Sampled: 9/8/16 7:18		Sample Composition: Raw Distribution Single		Matrix: Drinking Water		
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	0.0128	0.0020	0.015	09/21/16 16:46





**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 09/26/2016  
Received: 09/08/2016  
Sampled By: Rick Dettwyler  
Work Order: 6252035

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # : 4190529

Sampling Location: Rural Dell 10500 S Hyway 211\*

**Lab Number**

Lab Number	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>6252035-07</b>	Sample Name: Rm 7 Sampled: 9/8/16 7:20		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0121	0.0020	0.015	09/21/16 16:46
<b>6252035-08</b>	Sample Name: Rm 8 Sampled: 9/8/16 7:22		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0083	0.0020	0.015	09/21/16 16:46
<b>6252035-09</b>	Sample Name: Rm 9 Sampled: 9/8/16 7:25		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0024	0.0020	0.015	09/21/16 16:46
<b>6252035-10</b>	Sample Name: Rm 10 Sampled: 9/8/16 7:28		Sample Composition: Raw Distribution Single				Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/21/16 15:47
†Lead	1030	EPA 200.9	mg/L	0.0046	0.0020	0.015	09/21/16 16:46

**MCL** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit

**MCL** = Maximum Contamination Limit

†All procedures for this analysis conform to NELAC standards.

Approved by:

Adriana Gonzalez-Gray  
Laboratory Director