



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 06/24/2016

Received: 06/15/2016

Sampled By:

Work Order: 6167025

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # :

Sampling Location:

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6167025-11</b>	<b>Sample Name:</b> Molalla Middle 6th Grade DF <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-12</b>	<b>Sample Name:</b> Molalla Middle D.F. Hall by Rm 26 <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-13</b>	<b>Sample Name:</b> Molalla Middle Kitchen <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-14</b>	<b>Sample Name:</b> Molalla Middle Cafe. DF <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-15</b>	<b>Sample Name:</b> Land Lab fountain <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-16</b>	<b>Sample Name:</b> Molalla H. School Kitchen <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-17</b>	<b>Sample Name:</b> Molalla H. School commons DF. <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-18</b>	<b>Sample Name:</b> Molalla H. School Capasso D.F. <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-19</b>	<b>Sample Name:</b> Molalla H. School New Wing by Elev. D.F. <b>Sampled:</b> 6/15/16 0:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
†All procedures for this analysis are in accordance with NELAP standards.