



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/14/2016
Received: 06/29/2016
Sampled By: Frederic Dettwyler
Work Order: 6181014

C Molalla River School District
L Attn: -
I PO Box 188
E Molalla OR, 97037
N Phone: (503) 829-2359
T

Project:
Project # : N/A
PWSID # : 41 90529

Sampling Location: MRSD

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6181014-01	Sample Name: Mulino Kitchen Sink		Matrix: Water				
	Sampled: 6/28/16 14:10						
†Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	07/11/16 16:33
6181014-02	Sample Name: MES Rm 15		Matrix: Water				
	Sampled: 6/28/16 14:00						
†Lead	1030	EPA 200.9	6.6	ppb	2.0	20 ppb	07/11/16 16:33
181014-03	Sample Name: MES Rm 16		Matrix: Water				
	Sampled: 6/28/16 14:01						
†Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	07/11/16 16:33


ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is an action level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/24/2016

Received: 06/15/2016

Sampled By:

Work Order: 6167025

C **Molalla River School District**
L Attn: -
I PO Box 188
E Molalla OR, 97037
N Phone: (503) 829-2359
T

Project:
Project # : N/A
PWSID # :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6167025-01	Sample Name: Mulino Fountain Hall by Lib.		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-02	Sample Name: Mulino Fountain Rm 8		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-03	Sample Name: Mulino Kitchen		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	06/23/16 16:53
6167025-04	Sample Name: Mulino So. Blvd. Breezway		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-05	Sample Name: MES Lobby Fountain		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-06	Sample Name: MES Rm 16 Fountain		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	06/23/16 16:53
6167025-07	Sample Name: MES Kitchen		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-08	Sample Name: MES Cafe. fountain		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-09	Sample Name: MES Rm 14 fountain		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-10	Sample Name: MES Rm 4 fountain		Matrix: Water				
	Sampled: 6/15/16 0:00						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53