

Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223 Tel.: (503) 639-9311 Fax: (503) 684-1588

C Molalla River School District

- L Attn: Tony Tiano
- I 412 S Sweigle Ave
- E Molalla OR, 97038
- N Molalia OR, 97038
- **T** Phone: (503) 915-5248

ANALYSIS REPORT

Reported: 01/25/2022 Received: 01/18/2022 Sampled By: Tony Tiano Work Order: 2018016

Project:

Project # : Sample Type :

Sampling Location: Molalla Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2018016-01	Sample Name: Water Pe Sampled: 1/17/22 14:08		Nesun	Units			Matrix: Drinking Water
+Lead	1030	EPA 200.9	57	ppb	20	15 ppb	01/20/22 16:09 MCLE
2018016-02	Sample Name: Water Po Sampled: 1/17/22 14:08	od R					Matrix: Drinking Water
+Lead	1030	EPA 200.9	39	ppb	4	15 ppb	01/20/22 16:09 MCLE
2018016-03	Sample Name: Sky Pod Sampled: 1/17/22 14:10	L					Matrix: Drinking Water
+Lead	1030	EPA 200.9	50	ppb	4	15 ppb	01/20/22 16:09 MCLE
2018016-04	Sample Name: Sky Pod Sampled: 1/17/22 14:10	R					Matrix: Drinking Water
+Lead	1030	EPA 200.9	39	ppb	4	15 ppb	01/20/22 16:09 MCLE
2018016-05	Sample Name: Earth Po Sampled: 1/17/22 14:12	d L					Matrix: Drinking Water
+Lead	1030	EPA 200.9	30	ppb	2	15 ppb	01/20/22 16:09 MCLE
2018016-06	Sample Name: Earth Pod R Sampled: 1/17/22 14:12						Matrix: Drinking Water
+Lead	1030	EPA 200.9	131	ppb	20	15 ppb	01/20/22 16:09 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

+All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: Adriana Gonzalez-Gray Laboratory Director